

PRODUCT-TYPE TEST

The applicant:

INTUF, S.A.
CARRETERA MURCIA – ALICANTE KM 49 500
ES- 03330 CREVILLENTE
ALICANTE (ESPAÑA)

In compliance with the Regulation (UE) No. 305/2011 laying down harmonised conditions for the marketing of construction products, has performed reaction to fire type testing in:



aitex
textile research institute

Notified Testing Laboratory No. 0161

Document No. 09AN9215

Attending the set conditions por the CE marking detailed at Annex ZA of the harmonised product standard **EN 14041:2004 + AC:2007**, the notified laboratory declares on its classification report No. 2009AN9215 that the **floor covering** referenced as:

“CASTOR”

has been tested according to the requirements described at product standard, achieveing the EN 13501-1:2007+A1:2009 classification


“B_{FL}-s1”

Product, tests and field of application details are stated on the annex A of this document.

Alcoy, december 21st 2009.

Raquel Muñoz González
CHIEF OF INNOVATION AREA

Jordi Ferri Pascual
HEAD OF FIRE DEPARTMENT



TYPE TESTING – Annex A

A.1 PRODUCT-TYPE DETAILS

A.1.1 General:

Woven textile floor covering with pile and synthetic backing.

A.1.2 Product description provided by the applicant:

Composition	Fabric 100% wool // Backing 100% latex with action back PP
Weight	2750 g/m ²
Thickness	8,6 mm

A.2 CLASSIFICATION REPORT

Laboratory identification	Product reference	Report reference	Achieved classification
AITEX	CASTOR	2009AN9215	B _F L-s1

A.3 FIELD OF APPLICATION OF THE CLASSIFICATION

This classification might be affected if any of the following influence parameters is modified:

A.2.1. Product parameters:	
Composition	Fabric 100% wool // Backing 100% latex with action back PP
Thickness	8,6 mm, according to client
Density / Weight	2750 g/m ² , according to client
Surface structure	Product-type surface structure
Colour	Colour and design of floor coverings don't have any influence on its fire behaviour except for when this modification entail a composition or other parameters change.
A.2.2. End use applications:	
Orientations	Installations in any orientation
Fixing	Glued using vinyl adhesive.
Substrates	Non combustible (Euroclass A2-s1d0 or better) with density higher than 1600 Kg/m ³ , thickness greater than 6 mm.
Service / Washing	Durable
Format / Size	Roll wall to wall

A.4 LIMITATIONS

The classification assigned to the product in this report is appropriate to a declaration of the performance by the manufacturer within the context of a system 3 assessment of constancy of performance and CE marking under the Construction Products Regulation according to clauses ZA.2.2 and ZA.3 of the harmonized product standard EN 14041:2004 + AC:2007.

The manufacturer has made a declaration, which is held on file. This confirms that the product's design requires no specific processes, procedures or stages (e.g. no addition of flame retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references to the manufacturer's factory production control that is aimed to be relevant to the samples tested and that will provide for their traceability.